



OVERVIEW

In today's competitive and fast pace environment, utilities and industries constantly pursue ways of optimizing Power system and Process performance capabilities, simultaneously ensuring safety and reliability of the system. iEngineering Australia is well-versed in performing design work and consulting studies to optimize power system performance and and investigate system events.

WHY CHOOSE US

- ✓ Energetic flexible and open minded team
- ✓ Highest quality service and support
- ✓ We are a trusted company with excellent and fast service

CONTACT US

☎ +61(0)28860 9645

✉ enquiries@iengaust.com.au

🌐 www.ieng.tech

SERVICES

- Power System Studies & Design
- Energy & Electrical Audit
- ASP L3 Design/ Substation and Industrial Design
- Earthing Studies & EMFI Analysis
- Hosting Studies for EV and Renewables
- Industrial Engineering
- Green & Renewable Energy
- HV Panel Design
- Battery Energy Storage System Design
- Maintenance Excellence & Costing
- Telecom

POWER SYSTEM ANALYSIS AND NETWORK STUDIES

iEngineering Australia has quality engineering professionals and is able to satisfy requirements of comprehensive power system analysis and network studies using power system simulation software.




The following studies are carried out for Renewables, Power plants, Oil and gas, Process industries etc.. with the help of powerful software tools and experienced engineering expertise.

iEngineering Design and Consultancy

LOAD FLOW ANALYSIS



- Equipment Loading
- Voltage Profile
- Reactive power
- Compensation Voltage Control
- Power Factor Correction
- Contingency Analysis

Name	Element Type	Number	P (MW)	Q (MVar)	U (kV)	U (p.u.)	Loading (%)	P (MW)	Q (MVar)	U (kV)
LN1-4	Line	3010	15.5486	-5.8232	71.2287	1.024032	0	15.5486	-5.8232	71.2287
LN1-5	Line	3011	5.5591	-5.8239	70.9872	1.024788	0	5.5591	-5.8239	70.9872
TM1-10	20 transformer	1010	425721	3.3945	46.9241	40.19676	87.9	425721	3.3945	46.9241
TM1-10	20 transformer	701	-4	-5	186.54138	106.87324	83.35	0.02721	6.3964	186.54138
AD1-1	Asynchronous motor	701	4	5	186.54138	106.87676	78.40	0	0	186.54138
AD1-2	Asynchronous motor	8201	2	3	211.71038	127.63882	74.02	0	0	211.71038
TM1-10	20 transformer	301	898979	-6.6223	122.1199	106.1999	27.79	898979	-6.6223	122.1199
TM1-10	20 transformer	1010	10	10	224.2254	127.1705	25.28	224.2254	10	224.2254
QAD10-10	Line	3010	2	2	14.8422	14.89603	0	0	0	14.8422
LN1-2	Line	7010	4.9589	-3.4583	51.5334	14.89688	0	4.9589	-3.4583	51.5334
LN1-3	Line	7008	-4.9554	-3.4586	51.86638	14.89616	0	-4.9554	-3.4586	51.86638
LN1-4	Line	7008	0.91621	0.9476	6.17096	3.11308	0	0.91621	0.9476	6.17096





SHORT CIRCUIT STUDIES

- Equipment short circuit rating
- Circuit Breaker Selection
- Insulation withstanding capabilities
- Relay setting calculation
- System condition under fault occurrence
- Optimization of grounding techniques
- Short circuit mitigation technique recommendation



MOTOR ACCELERATION STUDIES

- Static motor acceleration studies
- Dynamic motor acceleration studies
- Starter recommendations



iEngineering Design and Consultancy

ARC FLASH STUDIES


- Incident energy calculation
- Arc flash boundary level recommendation
- Label Generation



Arc Flash Hazard	
Appropriate PPE Required	
Stage level	10 kV
alignment Type	Node
ounding	Solid grounded System
orking distance	18.11 inch
ish protection boundary	6.13 ft
ident energy decisive	19.73 Cal/cm ²
'E level	3
quipment name	87CB01A



HARMONIC ANALYSIS

- VTHD and ITHD interference
- Filtering design and dimensioning recommendation
- Power quality enhancement





HOSTING CAPACITY

- Integrating dispersed generators
- Target grid planning
- Connection request
- Voltage control in distribution Grid



iEngineering Design and Consultancy





TRANSIENT STABILITY ANALYSIS

- Angular and voltage stability analysis
- Critical clearing time
- Mitigation technique recommendation

INSULATION COORDINATION

- Insulation level selection coordination
- Surge arrester placing suggestion
- Investigation of overvoltage in case of switching actions
- Transient modelling of power system components
- Study on lightning impulse overvoltage condition




OVERCURRENT PROTECTION

- All types of protective devices with a current-time characteristic can be entered
- Several protective functions can be assigned to each protective device
- Exact modelling of setting ranges
- Transferring Current Values
- Simulation of fault clearing procedure in meshed networks, involves also distance protection

iEngineering Design and Consultancy

CABLE SIZING

- Automatic selection of protection device rating and setting
- Sizing of one cable or any number of cables together (distributed radial network)
- Maximum length of selected cable type and section for which the criteria is still fulfilled
- Cable cross-section area and the maximum cable
- Length including voltage drop condition for normal and motor start operation
- Criteria for overload and short-circuit protection, tripping times etc.



ement results

Cable Sizing

LV Distribution

Header

Drag a column header and drop it here to group by that column

Name	Parallel systems	Cross-section mm ²	Maximum length m	V_drop for Loadflow %	V_min for Loadflow %	V_drop (Loadflow)?	V_drop for Motor-start %	V_min for Motor-start %	V_drop (h)
K-EN-U1	1	6	63	2.25	96.33		5.23	88.74	
K-EN-U2	1	16	85	2.02	96.56		5.36	88.62	
K-EN-HVT	1	25	86	1.06	98.58		3.4	93.98	
K-NN-U2	1	3	54	2.1	96.04		2.11	95.86	
K-NN-U1	1	4	34	1.62	96.52		1.63	96.35	
K-NN-HVT	1	6	37	1.73	98.15		1.73	97.97	

iEngineering Design and Consultancy

STANDARD EXPERTISE

Load Flow Analysis

- IEEE 399-1997-IEEE Renewables Practice for Industrial and Commercial Power System Analysis

short Circuit Analysis

- IEC 60909 -2016-short circuit current in three-phase AC system
- IEC 61363-1998-Electrical installation of ships, mobile and fixed offshore unit ANSI C37

Motor Acceleration Studies

- IEEE-399-1997-IEEE recommended practice for Industrial and Commercial Power System Analysis
- NEMA-2016- National Electrical Manufactures Association

Overcurrent Protection

- IEEE-242-2001-IEEE recommended practice for Protection and Coordination of Industrial and Commercial Power System Analysis
- IEC-60255-2018-International Standard for Measuring Relays and Protection Equipment

Arc Flash studies

- IEEE-1584-2018-Guide for performing Arc-Flash Hazard Calculation
- NEPA-70E-2018-Standard for Electrical safety in the workplace
- OSHA-Occupational Safety and Health Administration

Harmonic Analysis

- IEEE 519-2014-IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power system
- IEC 61400-Standard for testing and accessing power quality characteristics of grid connected wind energy converter

Insulation Coordination

- IEC-60071-2018-Standard for Insulation Coordination
- IEEE C62.82.1-IEEE Standard For Insulation Coordination-Definitions, Principles and Rules

Cable Sizing

- AS/NZS-3008.1 and AS/NZS-3000
- IEC-60287

iEngineering Design and Consultancy

KEY PROJECTS EXECUTED

Power System Studies (Load Flow, Short Circuit, Relay Coordination and Arc Flash studies)

- Cockatoo Mine Power System Project
- Gencom-Mt Sugar SWER including protection setting
- Three 7 MW Mildura solar Generator in VIC
- Abu Hamour Mall and Doha Mall, Qatar
- FRA 54.4 Data Centre, Ireland
- BUWAIB Water treatment, Riyadh, Kingdom of Saudi
- Arabia Hero R&D and Production, India
- Tasek Cement Plant, Malaysia
- 660 MW Thermal Power Plant TPCIL, India.



Contingency Analysis and Power Evacuation Studies

- Uniten 50 MW Solar Power Plant, Malaysia
- Interconnection of 30 MWAC PV Power Plant,
- Malaysia 98 MW Hydro Power Plant, Kandi Malaysia
- Senvion Wind Farm, India.



Transformer Energization Studies

- Dubin Gas Plant, Ireland.

